

TRAVIS PERKINS GROUP
DECLARATION OF PERFORMANCE

No: 5060235344497.00

1. Product Type: Flat D Towel Rail 500mm x 750mm Chrome

2 Unique Identification Code(s): 825609 223301 BCS85CP3 425200CP

3. Intended use of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer: Radiator for connection to and use within a hydronic sealed central heating system.

4. Manufacturer:
Manufactured by TPPLC
Lodge Way House
Harlestone Road
Northampton
NN5 7UG

5. Authorised Representative:

6. System of System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V of the CPR: System 3

7. Harmonised Standard: EN442-1 - EN442-2 - EN442-3

8. Notified Body: Tested by Politecnico Di Milano - Dipartimento Di Energia, Laboratorio Misure Ricerche Termotecniche - Notified Body 1695

9. Declared Performance

Essential Characteristic	Performance	Harmonised Technical Specification
Leak Test	1300kPa	EN442-1 - EN442-2 - EN442-3
Strength Pressure Test	1690kPa	
Declared Maximum Working Pressure	1000kPa	
Reaction to Fire	Class A1	
Thermal Output Test	228 Watts / 778 BTU	
Durability Test	Pass	
100 Hour Humidity Test	Pass	

- 10.** The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Name and function: Stuart Croucher – Director of Group Quality

Place and date of issue: Lodge Way House, Northampton, NN5 7UG

09/07/2013

Signature:

A handwritten signature in black ink, appearing to be 'Stuart Croucher', written over a horizontal line.