

Sentinel X400 Rapid-Dose™

Thorough cleaner for systems older than six months

To remove built-up magnetite sludge, to restore circulation to radiators and pipework and to prepare for the installation of new components, major boiler manufacturers recommended that older systems should be cleaned with Sentinel X400 High Performance Cleaner. For pressurised systems the ideal method of dosing is by using Rapid-Dose.

- **High cleaning power**

Restores system circulation and system effectiveness

- **Long acting formula**


Holds sludge in suspension for up to approximately 3-4 weeks, ideal for pre-dosing

- **High performance dispersants**

Penetrates and lifts stubborn sludge ready for removal from system

- **Dose in 30 seconds into pressurised systems**

Ideal for pre-dosing ahead of the job



The Sentinel System

Lifetime protection for heating and hot water systems using the best practice process of...



CLEAN
WITH
APPROPRIATE
CLEANER



PROTECT
WITH X100
INHIBITOR



MAINTAIN
WITH
TEST KIT

Application

Sentinel X400 Rapid-Dose™ has been formulated for the effective cleaning of fouled central heating systems which may contain corrosion debris and other sludge. It is ideal for use where a new boiler or pump is to be fitted to an existing system, or where radiators have cold areas or are partly blocked due to sludge build up. The product is a non-acid formulation which can be used in all types of indirect heating systems including those containing aluminium components.

Dosing

One can of Sentinel X400 Rapid-Dose™ is sufficient to clean a typical domestic system of 8 to 10 radiator panels. Larger systems should be dosed with two cans. The product can be applied via the filling loop stop valve or radiator. The system should be less than 2.3 bar when the product is applied. Never attempt to dose into a hot system.

To clean an existing system in accordance with BS7593, Sentinel X400 Rapid-Dose should be circulated, preferably at normal operating temperature, with all valves open and the pump turned to maximum flow for a minimum period of 2 hours or until satisfactory performance is restored. Where systems are badly fouled, a longer period of circulation (approximately 3-4 weeks) is recommended. There is no limit to the time for which the product can safely be left in the system. Flush the system before refilling and dosing with Sentinel X100 Rapid-Dose.™

Physical properties

Specific gravity:	1.07 (25°C)
pH (concentrate):	6.2 (approx.)
Freezing point:	-9°C
Odour:	Mild

Safety precautions

The information provided overleaf enables compliance with the Control of Substances Hazardous to Health Regulations. A full Safety Data Sheet is available upon request.

Description	High Performance Cleaner for Central Heating Systems An aqueous solution of synthetic organic polymers.
Health hazards	Not for use in potable water systems. Not considered hazardous to health.
Handling	Avoid contact with skin and eyes. Keep out of reach of children and animals.
Storage	Store in cool, well ventilated area. Pressurised container. Protect from sunlight and do not expose to temperatures exceeding 50°C. Do not pierce or burn, even after use.
Spillage	Flush spillage with plenty of water and wash to waste.
Fire/explosion risks	Non-flammable
First aid	Skin Exposure: Wash immediately with plenty of water. If irritation develops, seek medical attention. Eye Exposure: Flush immediately with plenty of running water. Keep eyelids apart. Seek medical advice. Ingestion: Rinse mouth with water. Do NOT induce vomiting! Seek medical advice.

The use of Sentinel water treatment is endorsed by the industry's major international manufacturing companies*



Sentinel Performance Solutions Ltd

7650 Daresbury Park, Warrington, Cheshire, WA4 4BS, United Kingdom.

Tel: +44 (0)1928 704 330 www.sentinelprotects.com

