

**TRAVIS PERKINS GROUP**  
**DECLARATION OF PERFORMANCE**

No: 5060235344596.00

**1. Product Type:** Curved D Towel Rail 600mm x 1200mm Chrome

**2 Unique Identification Code(s):** 825625 BCC126CP3 425320CP

**3. Intended use of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:** Radiator for connection to and use within a hydronic sealed central heating system.

**4. Manufacturer:**  
Manufactured by TPPLC  
Lodge Way House  
Harlestone Road  
Northampton  
NN5 7UG

**5. Authorised Representative:**

**6. System of System or systems of assessment and verification of constancy of performance of the construction product as set out in Annex V of the CPR:** System 3

**7. Harmonised Standard:** EN442-1 - EN442-2 - EN442-3

**8. Notified Body:** Tested by Politecnico Di Milano - Dipartimento Di Energia, Laboratorio Misure Ricerche Termotecniche - Notified Body 1695

**9. Declared Performance**

Essential Characteristic	Performance	Harmonised Technical Specification
Leak Test	1300kPa	EN442-1 - EN442-2 - EN442-3
Strength Pressure Test	1690kPa	
Declared Maximum Working Pressure	1000kPa	
Reaction to Fire	Class A1	
Thermal Output Test	386 Watts / 1317 BTU	
Durability Test	Pass	
100 Hour Humidity Test	Pass	

- 10.** The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

**Signed for and on behalf of the manufacturer by:**

**Name and function:** Stuart Croucher – Director of Group Quality

**Place and date of issue:** Lodge Way House, Northampton, NN5 7UG

09/07/2013

**Signature:**

A handwritten signature in black ink, appearing to be 'Stuart Croucher', written over a horizontal line.